

K.C.T. Consultancy Services®

Soil Testing and Material Testing

(State & Central Govt. Approved)

Regd. No. : AB/TC/Ren/E-I/5294

O.No. AB-Tender-5604-2012

NABL (ISO/IEC : 17025) Accredited

(scope of our accreditation available on www.nabl-india.org)



Ref. No. : KCT/MS/114/12/09-002/07
Test Report

Date : 09/12/14

To,
Pericon Premix Pvt.Ltd.
Ref : Your letter dated 14/10/2014
Sample ID : Pericon Mska Putty

Sub:- Testing of Wall Putty Sample supplied by you.

Dear Sir,

Please find herewith test result of wall putty sample supplied by you

Sr. No.	Description	Test Results
1	Compressive strength in Mpa at 28days	4.84
2	Setting time	
a	Initial Setting Time in min.	180.00
b	Final Setting Time in min.	425.00
3	Tensile strength at 28 days in Mpa	1.5
4	Shear Adhesion in KN	
a	Dry Condition after 24hr.	1.00
b	Dry Condition after 14 days	5.00
c	Heat ageing Condition	4.20
d	Wet Condition	3.50
5	Loose Dry Density in kg/cum	1010.0
6	Wet Density in kg/cum.	1776.00
7	Water absorption (%)	10.60

Remark:- 1) The sample was tested after addition of 36% water by weight for all test as per instruction giver by the client.

2) There is no Indian standard method available for the test procedure, though test was performed as per the available relevant standard method on the specific instruction given by the client

3) Results reflect the properties of samples supplied to us and in the condition when supplied to us.

4) The certificate shall not be used for publicity / Product promotion etc. Results shall not be reproduced except in full.

5) We do not undertake or we shall not bound to participate or appear in any legal - court matter or litigation on any issues what so ever arise before or after submission of this certificate.

6) Sample are used while testing and therefore will not be available for inspection after testing.

Thanking you,

Yours faithfully,

For KCT Consultancy Services.

(Dr. K.C.Thaker)



LXXVII

Contact : Prof.Dr. K.C. Thaker / Dr. K.K. Thaker

Regd. Office & Lab :- 'KCT HOUSE', Shayona Silver Estate Part-2, B/h. Silver Oak College of Engineering, Nr. Lambda, Beside Auda Water Tank, S.G.Road, Gota, Ahmedabad - 382 481.

Tel. : 079-65103088-89-90, Mobile : 98250 64378, E-mail : kctconser@yahoo.com / kct@kctcs.in, Website : www.kctcs.in