



PERLCON
INNOVATE. CHANGE. LEAD.

Certificate of Analysis

TO WHOMSOEVER IT MAY CONCERN

Run Date : 01.02.2019

Product Name: - Maska Putty

MFD. : - P901/01.01.2019

Pack Size : - 40 kg.

Test	Specification	Reference	Test Result
Whiteness	>70%	IS: 8042-1989	86.3
Residue on 240 mesh	Max. 3%	IS4031 Part - 1	1.05
Dry Density	900 – 1100 kg/m ³	IS : 918 -1985	1022
Water Demand	30 – 45%	IS:4031(Part-4)1988	37
Wet Density	1450 - 1650Kg/m ³	PPPLQAWI -006	1581
Workability	Good	Should be spread easily	Good
Spread Mesh	14 – 18 cm	PPPLQAWI -011	16
Setting Time : Initial	>=30minutes	IS:4031(part-5):1988	195
Setting Time : Final	<=600 minutes	IS:4031(part-5):1988	290
Dry Adhesion:	Min 0.7 MPa	EN 1015-12	1.03
CompressiveStrength: 28 Days	CS I --- 0.4 to2.5 , CS II—1.5 to 5, CS III--- 3.5 to 7.5 CS IV--- >6	EN 1015-11:1999	8.11
Flexural Strength: 28 Days	>1.5 MPa	EN 1015-11:1999	2.2

APPROVED BY
NAWNIT SHARMA
ASST. MANAGER QA
MANAGER

VERIFIED BY:
PIYUSH MODI
PRODUCTION